

THE CITY OF REDMOND FIRE DEPARTMENT - PREVENTION DIVISION

International Fire Code Administrative Ruling / Interpretation



Code Section: IFC 1504.6 Standard Edition: 2003

Title: Spray Booth Fire Protection Requirements

Date: March 2, 2005

Statement of Need:

Clarification of International Fire Code Section 1504.6: Spray booths and spray rooms shall be protected by an approved automatic fire extinguishing system.

Ruling/Interpretation:

The City of Redmond Fire Department requires an approved automatic fire sprinkler system for protection of spray booths and their associated ducting.

Exception: In buildings where no fire sprinkler system is installed or an adequate water supply for sprinkler protection of the booth is not currently available in the building, the Fire Marshal may approve an alternate automatic fire extinguishing system for protection of the spray booth.

Robert Lovett
Fire Marshal

O:\Prevention\Development\Administrative Rulings & Interpretations & Standard Revisions\Finalled\IFC\IFC\1504.6.doc